

Montgomery County Public Schools Lead in Drinking Water Testing Report

William Tyler Page Elementary School
13400 Tamarack Rd.
Silver Spring, MD 20904

Report Date: April 30, 2025

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the State Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by KCI Technologies, Inc. is presented in the table below.

| | |
|---------------------------|-----------|
| Sampling Date | 3/20/2025 |
| # of Outlets Tested | 44 |
| # of Outlets \geq 5 ppb | 7 |

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be shut-down within 24 hours, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass outlets, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for William Tyler Page ES

| Outlet Barcode | Outlet Location | Outlet Type | Initial Results (ppb) | Pass/Fail | Status |
|----------------|--|--|-----------------------|-----------|-------------------------|
| LW04441 | In Classroom A110 | Combination Sink - Fountain - Bubbler | <1.0 | Pass | Testing Complete |
| LW04443 | In Classroom A111 | Combination Sink - Fountain - Bubbler | 8.0 | Fail | Remediation Action Plan |
| LW04445 | In Classroom G101 | Combination Sink - Fountain - Bubbler | 3.0 | Pass | Testing Complete |
| LW04453 | In Hallway Next To C104 | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW04454 | In Hallway Outside Media Center | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW04458 | In Classroom C103 | Combination Sink - Fountain - Bubbler | <1.0 | Pass | Testing Complete |
| LW04460 | In Classroom C102 | Combination Sink - Fountain - Bubbler | <1.0 | Pass | Testing Complete |
| LW04462 | In Classroom C101 | Combination Sink - Fountain - Bubbler | <1.0 | Pass | Testing Complete |
| LW04464 | In Classroom A106 | Combination Sink - Fountain - Bubbler | 6.2 | Fail | Remediation Action Plan |
| LW04465 | In Classroom A107 | Combination Sink - Fountain - Bubbler | <1.0 | Pass | Testing Complete |
| LW04468 | In Classroom A108 | Combination Sink - Fountain - Bubbler | 1.4 | Pass | Testing Complete |
| LW04470 | In Classroom A116 | Combination Sink - Fountain - Bubbler | 15.1 | Fail | Remediation Action Plan |
| LW04472 | In Classroom E102 | Combination Sink - Fountain - Bubbler | <1.0 | Pass | Testing Complete |
| LW04473 | In Lobby Between Boys' And Girls' Bathroom | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW04475 | In Hallway Across From H209 | Bottle Filler/Drinking Fountain Combo Unit - Cooler/Chiller (Refrigerated) | <1.0 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initial Results (ppb) | Pass/Fail | Status |
|-----------------------|-------------------------------------|--|------------------------------|------------------|------------------|
| LW04479 | In Classroom H208 | Combination Sink - Fountain - Bubbler Style (Non-Refrigerated) | <1.0 | Pass | Testing Complete |
| LW04480 | In Staff Lounge | Faucet, Cold | 2.4 | Pass | Testing Complete |
| LW04483 | In Classroom H203 | Combination Sink - Fountain - Bubbler | <1.0 | Pass | Testing Complete |
| LW04485 | In Classroom H204 | Combination Sink - Fountain - Bubbler | <1.0 | Pass | Testing Complete |
| LW05187 | In Health Room | Combination Sink - Faucet, Cold | <1.0 | Pass | Testing Complete |
| LW05189 | In Hallway Across From Health Room | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW05191 | In Hallway Outside Media Center | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW10835 | In Hallway Across From H209 | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler | <1.0 | Pass | Testing Complete |
| LW13463 | In Lobby Corridor | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler | <1.0 | Pass | Testing Complete |
| LW13464 | In Lobby Corridor | Bottle Filler/Drinking Fountain Combo Unit - Cooler/Chiller (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW13470 | In Lobby Corridor | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW13471 | In Hallway Across From Media Center | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW13473 | In Office F104 | Combination Sink - Fountain - Bubbler | 1.8 | Pass | Testing Complete |
| LW13474 | In Hallway Across From A115 | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW13475 | In Hallway Next To A107 | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW13761 | In Health Room | Combination Sink - Fountain - Bubbler | 3.5 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initial Results (ppb) | Pass/Fail | Status |
|-----------------------|-----------------------------|---|------------------------------|------------------|-------------------------|
| LW13762 | In Hallway Across From L204 | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW13763 | In Hallway Across From L204 | Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| LW13764 | In Hallway Across From L204 | Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler | <1.0 | Pass | Testing Complete |
| LW13826 | In Kitchen | Faucet, Cold | 5.5 | Fail | Remediation Action Plan |
| M35458 | In Classroom H205 | Combination Sink - Fountain - Bubbler | 6.4 | Fail | Remediation Action Plan |
| M35460 | In Classroom H201 | Combination Sink - Fountain - Bubbler | <1.0 | Pass | Testing Complete |
| M35462 | In Classroom H202 | Combination Sink - Fountain - Bubbler | 8.8 | Fail | Remediation Action Plan |
| M35467 | In Hallway Across From H204 | Drinking Water Fountain - Cooler/Chiller Style (Refrigerated) | <1.0 | Pass | Testing Complete |
| M35500 | In Classroom A115 | Combination Sink - Fountain - Bubbler | 1.2 | Pass | Testing Complete |
| M36198 | In Kitchen | Faucet, Cold | 9.8 | Fail | Remediation Action Plan |
| M36199 | In Kitchen | Commercial Kitchen Kettle, Cold | 4.4 | Pass | Testing Complete |
| M36200 | In Kitchen | Faucet, Cold | <1.0 | Pass | Testing Complete |
| M36201 | In Kitchen | Faucet, Cold | <1.0 | Pass | Testing Complete |

Montgomery County Public Schools Lead in Drinking Water Testing Report

**William Tyler Page Elementary School
13400 Tamarack Road
Silver Spring, MD 20904**

Report Date: July 27th, 2022

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the Montgomery County Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by SaLUT are presented in the table below.

| | |
|---------------------------|------------|
| Sampling Date | 05/24/2022 |
| # of Outlets Tested | 54 |
| # of Outlets \geq 5 ppb | 4 |

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be immediately shut-down, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for William Tyler Page ES

| Fixture Barcode | Fixture Location | Fixture Type | Initial Results (ppb) | Pass/Fail | Follow up Results (ppb) | Status |
|-----------------|---|---|-----------------------|-----------|-------------------------|------------------|
| LW04438 | In classroom A106 | Classroom Combination Sink | 3.2 | Pass | N/A | Testing Complete |
| LW04440 | In classroom A109 | Classroom Combination Sink | 1.1 | Pass | N/A | Testing Complete |
| LW04442 | In classroom A110 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| LW04444 | In classroom A111 | Classroom Combination Sink | 2.2 | Pass | N/A | Testing Complete |
| LW04445 | In reading G101 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW04451 | In classroom C-104 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| LW04453 | In hallway C104 by classroom ie. outside of | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW04454 | In hallway by media center | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW04455 | In reading G101 | Teacher's Lounge Sink | <1 | Pass | N/A | Testing Complete |
| LW04456 | In hallway A114 across from | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW04458 | In classroom C-103 | Classroom Combination Drinking Fountain | 2.8 | Pass | N/A | Testing Complete |
| LW04459 | In classroom C-103 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| LW04460 | In classroom C-102 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW04461 | In classroom C-102 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| LW04462 | In classroom C-101 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW04463 | In classroom C-101 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| LW04465 | In classroom A107 | Classroom Combination Sink | 1.2 | Pass | N/A | Testing Complete |
| LW04466 | In classroom A107 | Classroom Combination Drinking Fountain | 3.2 | Pass | N/A | Testing Complete |
| LW04467 | In classroom A108 | Classroom Combination Sink | 1.1 | Pass | N/A | Testing Complete |
| LW04471 | In day care A117 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| LW04472 | In day care A117 | Classroom Combination Drinking Fountain | 23.9 | Fail | N/A | Testing Complete |
| LW04473 | In hallway | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW04474 | In hallway | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW04475 | In hallway H209 across from | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW04476 | In classroom H209 | Classroom Combination Sink | 2.2 | Pass | N/A | Testing Complete |
| LW04478 | In classroom H208 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| LW04479 | In classroom H208 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW04480 | In team room | Teacher's Lounge Sink | 2.2 | Pass | N/A | Testing Complete |
| LW04481 | In classroom H207 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| LW04483 | In classroom H203 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |

| | | | | | | |
|---------|---|---|------|------|-----|------------------|
| LW04484 | In classroom H204 | Classroom Combination Sink | 1.2 | Pass | N/A | Testing Complete |
| LW04485 | In classroom H204 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW05187 | In health room | Nurses Office Sink | <1 | Pass | N/A | Testing Complete |
| LW05188 | In hallway by health room ie. across from | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW05189 | In Lob by by gymnasium ie. outside of | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW05190 | In Lob by by cafeteria ie. outside of | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW05191 | In hallway by media center ie. outside of | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW10835 | In hallway across from classroom H209 | Bottle Filler | <1 | Pass | N/A | Testing Complete |
| LW10836 | In hallway by gymnasium | Bottle Filler | <1 | Pass | N/A | Testing Complete |
| LW10837 | In hallway by cafeteria | Bottle Filler | <1 | Pass | N/A | Testing Complete |
| LW10838 | In hallway by cafeteria | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| LW10839 | In hallway by cafeteria | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M35455 | In classroom H206 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M35457 | In classroom H205 | Classroom Combination Sink | 2.0 | Pass | N/A | Testing Complete |
| M35458 | In classroom H205 | Classroom Combination Drinking Fountain | 28.3 | Fail | N/A | Testing Complete |
| M35459 | In classroom H201 | Classroom Combination Sink | 2.4 | Pass | N/A | Testing Complete |
| M35460 | In classroom H201 | Classroom Combination Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M35461 | In classroom H202 | Classroom Combination Sink | 1.1 | Pass | N/A | Testing Complete |
| M35462 | In classroom H202 | Classroom Combination Drinking Fountain | 3.4 | Pass | N/A | Testing Complete |
| M35463 | In classroom H203 | Classroom Combination Sink | <1 | Pass | N/A | Testing Complete |
| M35467 | In hallway H204 outside CR H204 | Drinking Fountain | <1 | Pass | N/A | Testing Complete |
| M35499 | In resource center A114 | Classroom Combination Sink | 20.9 | Fail | N/A | Testing Complete |
| M35500 | In resource center A114 | Classroom Combination Drinking Fountain | 6.2 | Fail | N/A | Testing Complete |



Montgomery County Public Schools Lead in Drinking Water Testing 2018

April 30, 2018

Executive Summary:

William Page Elementary School

13400 Tamarack Road

Silver Spring, Maryland 20904

| | |
|-----------------------------|---------|
| Round of Testing: | Initial |
| # of Outlets Tested: | 62 |
| # of Outlets \geq 20 ppb: | 0 |
| Low Value (ppb): | <1.0 |
| High Value (ppb): | 8.5 |

Project Status:

Initial testing complete: All results less than 20 ppb.



April 30, 2018

Mr. Brian Mullikin, MS
Environmental Team Leader
Montgomery County Public Schools
Division of Maintenance
Gaithersburg, Maryland 20879

Re: Drinking Water Testing

KCI Job #1214634191

Location: William Page Elementary School

13400 Tamarack Road
Silver Spring, Maryland 20904

Dear Mr. Mullikin:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of Initial lead in water testing at William Page Elementary School, located at 13400 Tamarack Road in Silver Spring, Maryland 20904.

SCOPE OF SERVICES

KCI conducted lead in water testing at William Page Elementary School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

KCI visited the site on 4/4/2018 and 4/5/2018 to collect samples from 62 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water - Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

RESULTS

There are no results of the lead in water analysis at or above 20 parts per billion (ppb). The lead in water sample results for sample collection date 4/5/2018 are shown in Attachment A.

DISCUSSION

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children's brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990's could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,
KCI Technologies, Inc.



Kamau McAbee
MDE Certified Water Sampler #8281KM

Attachment:

A- Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

Contractor: KCI Technologies, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Sample Results for William Page Elementary School

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB)* | Pass/Fail | Status |
|------------|--------|----------------------|----------------|------------------|----------------|-----------|------------------|
| LW04438 | A106 | Classroom | | Faucet | 2.1 | Pass | Testing Complete |
| LW04439 | A109 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04440 | A109 | Classroom | | Faucet | 1.6 | Pass | Testing Complete |
| LW04441 | A110 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04442 | A110 | Classroom | | Faucet | 1.3 | Pass | Testing Complete |
| LW04443 | A111 | Classroom | | Bubbler - Indoor | 1.0 | Pass | Testing Complete |
| LW04444 | A111 | Classroom | | Faucet | 4.4 | Pass | Testing Complete |
| LW04445 | G101 | Reading | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04451 | C-104 | Classroom | | Faucet | 2.9 | Pass | Testing Complete |
| LW04452 | C-104 | Classroom | | Bubbler - Indoor | 1.3 | Pass | Testing Complete |
| LW04453 | C104 | Hallway Classroom | Outside Of | Cooler | <1.0 | Pass | Testing Complete |
| LW04454 | | Hallway Media Center | | Cooler | <1.0 | Pass | Testing Complete |
| LW04455 | G101 | Reading | | Faucet | <1.0 | Pass | Testing Complete |
| LW04456 | A114 | Hallway | Across From | Cooler | <1.0 | Pass | Testing Complete |
| LW04458 | C-103 | Classroom | | Bubbler - Indoor | 1.4 | Pass | Testing Complete |
| LW04459 | C-103 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| LW04460 | C-102 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04461 | C-102 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| LW04462 | C-101 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04463 | C-101 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| LW04464 | A106 | Classroom | | Bubbler - Indoor | 8.1 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB)* | Pass/Fail | Status |
|------------|--------|---------------------|----------------|------------------|----------------|-----------|------------------|
| LW04465 | A107 | Classroom | | Faucet | 1.3 | Pass | Testing Complete |
| LW04466 | A107 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04467 | A108 | Classroom | | Faucet | 1.6 | Pass | Testing Complete |
| LW04468 | A108 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04469 | A116 | Classroom | | Faucet | 2.4 | Pass | Testing Complete |
| LW04470 | A116 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04471 | A117 | Day Care | | Faucet | <1.0 | Pass | Testing Complete |
| LW04472 | A117 | Day Care | | Bubbler - Indoor | 1.2 | Pass | Testing Complete |
| LW04473 | | Hallway | | Cooler | <1.0 | Pass | Testing Complete |
| LW04474 | | Hallway | | Cooler | <1.0 | Pass | Testing Complete |
| LW04475 | H209 | Hallway | Across From | Cooler | <1.0 | Pass | Testing Complete |
| LW04476 | H209 | Classroom | | Faucet | 1.4 | Pass | Testing Complete |
| LW04477 | H209 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04478 | H208 | Classroom | | Faucet | 1.7 | Pass | Testing Complete |
| LW04479 | H208 | Classroom | | Bubbler - Indoor | 1.4 | Pass | Testing Complete |
| LW04480 | | Team Room | | Faucet | <1.0 | Pass | Testing Complete |
| LW04481 | H207 | Classroom | | Faucet | 3.3 | Pass | Testing Complete |
| LW04482 | H207 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04483 | H203 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW04484 | H204 | Classroom | | Faucet | 1.9 | Pass | Testing Complete |
| LW04485 | H204 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| LW05187 | | Health Room | | Faucet | <1.0 | Pass | Testing Complete |
| LW05188 | | Hallway Health Room | Across From | Cooler | <1.0 | Pass | Testing Complete |
| LW05189 | | Lobby Gymnasium | Outside Of | Cooler | <1.0 | Pass | Testing Complete |
| LW05190 | | Lobby Cafeteria | Outside Of | Cooler | <1.0 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB)* | Pass/Fail | Status |
|------------|--------|----------------------|-----------------|------------------|----------------|-----------|------------------|
| LW05191 | | Hallway Media Center | Outside Of | Cooler | <1.0 | Pass | Testing Complete |
| M35455 | H206 | Classroom | | Faucet | 1.5 | Pass | Testing Complete |
| M35457 | H205 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M35458 | H205 | Classroom | | Bubbler - Indoor | 3.2 | Pass | Testing Complete |
| M35459 | H201 | Classroom | | Faucet | 1.5 | Pass | Testing Complete |
| M35460 | H201 | Classroom | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M35461 | H202 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M35462 | H202 | Classroom | | Bubbler - Indoor | 1.4 | Pass | Testing Complete |
| M35463 | H203 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M35467 | H204 | Hallway | Outside Cr H204 | Cooler | <1.0 | Pass | Testing Complete |
| M35499 | A114 | Resource Center | | Faucet | 2.7 | Pass | Testing Complete |
| M35500 | A114 | Resource Center | | Bubbler - Indoor | <1.0 | Pass | Testing Complete |
| M36199 | | Kitchen | | Faucet | 8.5 | Pass | Testing Complete |
| M36200 | | Kitchen | | Faucet | 4.3 | Pass | Testing Complete |
| M36201 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| M36202 | | Kitchen | | Faucet | 1.5 | Pass | Testing Complete |

*PPB = parts per billion